

## ADDITIONAL INFORMATION

**Fire Extinguisher:** “*Florida certified*” means *Inspected and Tagged by a Florida Certified Fire Equipment Company. There are a number of companies listed in the telephone directory, under the listing of “Fire Extinguishers”.*

*Fire extinguishers **DO NOT** come from the factory certified.*

*Fire extinguishers may be purchased from any retail store and taken to one of these companies for certification. You may also purchase extinguishers from one of these companies.*

**\*\*\*NOTE \*\*\***

*The Fire Department **DOES NOT** certify fire extinguishers.*

**Approved Safety Can:** This refers to “**Steel Safety cans**” used for the storage and / or transport of flammable liquids – gasoline, kerosene, diesel fuel, and weed eater mix fuels. Check with your local equipment dealer for further information.

## INFORMATION

The following programs are available by contacting the **Deltona Fire Department, Public Education Division** at  
(386) 575-6921


- Burn Prevention class
- Fire Extinguisher Class
- CPR Classes
- Fire Station Tours
- Speakers for clubs and groups
- Babysitting Classes

The following programs are available by contacting the **Building & Enforcement Services, Fire Safety Division** at  
(386) 878-8655 or (386) 878-8656

- Juvenile Fire Setter program
- Hydrant locations
- Statistics and reports
- Fire Code information

**City of Deltona  
Building & Enforcement Services  
Fire Safety Division**

**“Be Proactive, not reactive towards  
Fire Safety”**



Help us protect your business

### **BEFORE A FIRE STARTS**

Fire Safety Requirements for

### **RESIDENTIAL LOCAL BUSINESS TAX RECEIPT**

The **City of Deltona Building & Enforcement Services Department, Fire Safety Division** will be conducting a Fire Safety Inspection at your residential business on

### **MONDAY, WEDNESDAY OR FRIDAY**

Between 8:30 AM & 12:00 NOON

To schedule an inspection, please contact the **Business Tax Department** at  
(386) 878-8560

To reschedule or cancel appointments only, please contact:

The **Building & Enforcement Services** office at  
(386) 878-8656 Monday thru Friday  
7:30 AM TO 4:30 PM

# Residential Local Business Tax Receipt Self-Inspection Checklist

**Reference Codes used** – Florida Fire Prevention Code 2010 edition and City Ordinance  
**Business Occupancies** – are those used for the transaction of business,  
keeping of accounts and records, and similar purposes.



**CITY ORDINANCE 110-807c** – The floor area devoted to the home occupation **SHALL NOT** exceed 25 percent of the floor area of the dwelling. However, up to 500 square feet in an

attached or detached garage of a dwelling, or in any accessory building in an agricultural classification, may be used for a home occupation in lieu of floor space within the dwelling.

**STREET NUMBERS** – The building (address) number **SHALL BE** affixed to the front of the building, or to a separate structure in front of the building (such as a mailbox, post, wall, fence, etc.), in such a manner so as to be


**clearly visible and legible** from the public or private way on which the building fronts. Numerals **SHALL BE** Arabic and **SHALL NOT** be less than three inches in height and one-half in width. of the building or structure on which such numerals are affixed.




**Street Numbers (cont'd)** - The numerals **SHALL BE** of a contrasting color with the immediate background of the building or structure on which such numerals are affixed. (City Ordinance, Sec. 18-265)



**FIRE EXTINGUISHER(S)** – There **SHALL BE** an ABC type fire extinguisher (minimum of a **3A-40BC**), “Florida Certified”, located in the residence. There **SHALL BE** a fire extinguisher located on all work trailers (minimum of a **3A-40BC** and “Florida Certified”).



**SMOKE DETECTION EQUIPMENT** – There **SHALL BE** an approved single-station or multiple station smoke detectors installed and operational within the residence. It is recommended at least 1 battery or dual powered detector be installed in the event of a power failure.



**ELECTRICAL CIRCUIT PANEL BOX** – All circuits **SHALL BE** identified, blanks in all unused circuits. Face plates **SHALL BE** on all outlets with **NO EXPOSED WIRING**. There **SHALL BE**

a 36-inch clearance in front of the circuit breaker panel, **NO** obstruction **SHALL BE** allowed.



**PROTECTION from HAZARDS** – Hazardous areas including but not limited to areas used for general storage, wood-working, and painting areas are recommended to be

separated from other parts of the residence in an outside structure not attached to the main residence, with a 10-foot separation. A maximum of **25 gallons** of flammable or combustible liquids can be stored.

All Flammable or Combustible liquids shall be stored in an

**APPROVED SAFETY CAN**. No plastic or glass containers shall be used.