

ADDITIONAL INFORMATION

Fire Extinguisher: “*Florida certified*” means Inspected and Tagged by a Florida Certified Fire Equipment Company. There are a number of companies available through the internet, under “Fire Extinguishers Volusia County”.

Fire extinguishers **DO NOT** come from the factory certified.

Fire extinguishers may be purchased from any retail store and taken to one of the Florida Certified Fire Equipment Companies for certification. Or, you may also purchase a “*Florida certified*” extinguisher from one of the Florida Certified Fire Equipment Companies.

***NOTE ***

The Fire Department **DOES NOT** certify fire extinguishers.

Approved Safety Can: This refers to “*Steel Safety cans*” used for the storage and/or transport of flammable liquids – gasoline, kerosene, diesel fuel, and weed eater mix fuels. Check with your local equipment dealer for further information.

INFORMATION

The following programs are available by contacting the **Deltona Fire Department**, at (386) 575-6901

- CPR
- Child and Babysitting Safety (CABS)
- Child Car Seat Safety
- Fire Extinguisher Safety Training Class
- Fire Safety Presentations
- Fire Station Tours
- Health and Safety Fairs
- Speakers for clubs and groups

The following programs are available by contacting the **Fire Inspection/Safety Division** at

(386) 878-8655 or (386) 878-8656

- Juvenile Fire Setter program
- Hydrant locations
- Statistics and reports
- Fire Code information

**City of Deltona Fire Department
Fire Inspection/Safety Division**

**“Be Proactive, not reactive towards
Fire Safety”**



Help us protect your business

BEFORE A FIRE STARTS

Fire Safety Requirements for

RESIDENTIAL BUSINESS TAX RECEIPT

The City of **Deltona Fire Department, Fire Inspection/Safety Division**, will be conducting a Fire Safety Inspection at your residential business on:

MONDAY, WEDNESDAY OR FRIDAY

Between 8:30 AM & 12:00 Noon

To schedule an inspection, please contact the Business Tax Office at (386) 878-8560

To reschedule or cancel appointments **ONLY**, please contact:

The **Fire Safety Division** office at (386) 878-8656, Monday thru Friday, 8:00 AM to 4:30 PM

Residential Local Business Tax Receipt Self-Inspection Checklist

Reference Codes used – Florida Fire Prevention Code Sixth Edition and City Ordinance
Business Occupancies – are those used for the transaction of business,
keeping of accounts and records, and similar purposes.



CITY ORDINANCE 110-807c – The floor area devoted to the home occupation **SHALL NOT** exceed 25 percent of the floor area of the dwelling. However, up to 500 square feet in an

attached or detached garage of a dwelling, or in any accessory building in an agricultural classification, may be used for a home occupation in lieu of floor space within the dwelling.

ADDRESS NUMBERS – The address numbers **SHALL BE** in a position to be **plainly legible and visible** from the street or road fronting the property. Address numbers **SHALL** contrast with their background. Address numbers


SHALL BE Arabic numerals or alphabet letters, and **SHALL NOT** be less than three inches in height.




Street Numbers (cont'd) - The numerals **SHALL BE** of a contrasting color with the immediate background of the building or structure on which such numerals are affixed. (City Ordinance, Sec. 18-265)



FIRE EXTINGUISHER(S) – There **SHALL BE** an ABC type fire extinguisher (minimum of a **3A-40BC**), “Florida Certified”, located in the residence. There **SHALL BE** a fire extinguisher located on all work trailers (minimum of a **3A-40BC** and “Florida Certified”).



SMOKE ALARM EQUIPMENT – There **SHALL BE** an approved single-station or multiple station smoke alarm(s) installed and operational within the residence. It is recommended at least 1 battery or dual powered alarm be installed in the event of a power failure.



ELECTRICAL CIRCUIT PANEL BOX – All circuits **SHALL BE** identified, blanks in all unused circuits. Face plates **SHALL BE** on all outlets with **NO EXPOSED WIRING**. There **SHALL BE** a 36-inch clearance in front of the circuit breaker panel, **NO** obstruction **SHALL BE** allowed.



PROTECTION from HAZARDS – Hazardous areas including but not limited to areas used for general storage, wood-working, and painting areas are recommended to be separated from other parts of the residence in an outside structure not attached to the main residence, with a 10-foot separation. A maximum of **25 gallons** of flammable or combustible liquids can be stored.

ALL Flammable or Combustible liquids shall be stored in an **APPROVED SAFETY CAN**. No plastic or glass containers shall be used.